

Trichloroacetic Acid µg/L

Dept of Human Services &
Australian Drinking Water
Guideline Value

Description

100 µg/L (0.1 mg/L)

Haloacetic Acids (HAA's) occur principally as a product of the reaction of chlorine with naturally occurring organic materials within the water supply. HAA's are made up of three principal groups; Chloroacetic Acid, Dichloroacetic Acid and Trichloroacetic Acid and is a by-product of the chlorination/chloramination process used to disinfect the water supply.

Feb-09						
Water Quality Locality	ID Number	Number of Samples	Mean value (mg/L)	Minimum Test Value	Maximum Value (mg/L)	Complies Y / N
Bulla	1	1	0.010		0.010	Y
Darley	2	1	0.013		0.013	Y
Diggers Rest	3	1	0.013		0.013	Y
Gisborne	4	1	0.005		0.005	Y
Lancefield	5	1	0.005		0.005	Y
Lerderberg	6	1	0.020		0.020	Y
Macedon	7	1	0.008		0.008	Y
Maddingley	8	1	0.016		0.016	Y
Melton South	9	1	0.017		0.017	Y
Merrimu	10	1	0.027		0.027	Y
Mount Macedon	11	1	0.010		0.010	Y
Myrning	12	1	0.005		0.005	Y
Riddells Creek	13	1	0.010		0.010	Y
Rockbank	14	1	0.021		0.021	Y
Romsey	15	1	0.005		0.005	Y
Sunbury	16	1	0.009		0.009	Y
Toolern Vale	17	1	0.005		0.005	Y
Woodend	18	1	0.005		0.005	Y
Business Total		18		-	-	-

